

**University of Illinois, Department of Agricultural and Biological Engineering
 Bioenvironmental and Structural Systems Lab
 Circulating Fan Performance - Final Report**

Project Number: c12085
Test Date: January 13, 2012

Fan:	Motor:	Guards:
Make- Termotecnica Pericoli	Make- ABB	Description- wire
Model- EOR42 / 0.75	Model - M2VA804	Spacing- 0.8" x 4" (20 x 100mm)
Size- 41.2" (1047 mm)	Hp- 0.75 (0.55 kW)	Location- intake / exhaust
Orifice \varnothing - 41.9" (1064 mm)	RPM- 1680 // 1400	
	Volts- 380-420/ 220-440	
Blade:	Amps- 1.4/2.4 // 1.5/2.6	
Number- 6	Hz- 60 // 50	
Shape- propeller	Phase- 3	
Material- aluminum	S.F. - -	

Drive Sheaves:	Housing: Box
Drive o.d.- 4.0" (102 mm)	Material: galvanized steel
Axle o.d.- 12" (307 mm)	Depth- 15.5" (395 mm)

Notes: 60 Hz test

5 x D Centerline Velocity (fpm): 930

Test Conditions:

T(wb): 50	Barometric pressure, recorded	29.18
T(db): 71	Barometric Pressure, corrected	29.07

D Impeller \varnothing (in.)	Thrust (lbf)	rpm	Volts	Amps	kW	Thrust Efficiency Ratio (lbf/kW)
41.2	13.65	524	229.4	2.3	0.743	18.4

Airflow* (thrust cfm)	(thrust cfm/W)
14200	19.1

*Airflow - ANSI/AMCA 230-12 Eq. 9.6 IP